Request for Board of Commissioners' Action

| From: | Faye Hughes, County Administrator | | | Date: | 0 | ctober 12, 2018 | | |
|----------|-----------------------------------|-------|-----------------|--------|--------------|-----------------|--------|--|
| Subject: | Communication | Tower | Bldg–Electrical | Quotes | Item Number: | V | /III-C | |

The following quotes were obtained by Lamar Ray. These quotes are for the electrical work that will be needed at the new 911 Communication Tower Building:

Premium Electric, LLC925.00McDaniel Electric, LLC1,527.00C & P Electrical & Plumbing2,375.00Cone Electric2,700.00

Chair will need a motion to accept the bid for electrical work for the 911 Communication Tower Building from ______.

| Motion made | e by | | |
|--------------|------|----|------------------------|
| Second made | e by | | |
| Any discussi | on: | | |
| Votes | yes | no | Motion carried/ failed |

Please submit a quote to me by October 1st for the following:

10 receptacles

đ

3 interior lights and switch

1 porch light and switch

100 service (back to back)

(lights on 1 breaker)

(A/C on receptacle on 1 breaker)

(each wall of receptacles will have it's on breaker)

Lamar Ray

Cook County E-911/EMA

3295 County Farm Rd

Adel, Ga. 31620

o-229-896-4464

f-229-896-8702

Premium Electric, LLC

P.O. Box 23 579 Wilkes Road Adel, GA 31620 229-560-0167

DATE 9/22/2018 QUOTE # 2018-009 CUSTOMER ID CCC VALID UNTIL

License # EN215850

CUSTOMER

Cook County 911 County Farm Rd Adel, GA 31620

| DESCRIPTION | TAXED | AMOUNT |
|--|---------------------|-----------|
| Provide labor and materials to wire 12x12 building tower building. | | 925.00 |
| Including: 100 amp panel box with 5 separate circuits 3 interior lights and 1 exterior light 10 plugs | | |
| | Subtotal | 925.00 |
| TERMS AND CONDITIONS 1.) Work will start after receiving signed acceptance of this quote below. | Taxable Tax rate | 7.000% |
| 2.) Half of balance will be due after passing rough-in inspection. | Tax due | - |
| 3.) Final balance will be due after passing final inspection. | Other | - |
| 4.) Invoices are due within 10 days of receipt. Customer Acceptance (sign below): | TOTAL | \$ 925.00 |

x ___

Print Name:

If you have any questions about this price quote, please contact Michael Felts at 229-560-0167 Thank You For The Opportunity!

QUOTE

.

ESTIMATE

| Lamar | Ray Coo | ok Co. | 911 |
|-------|---------|---------|-----|
| | (229) |) 869-4 | 464 |

.

| 2812 Hwy 76 Adel, Ga 31620 | Estimate # Date | 000221 09/18/2018 |
|---|---|----------------------|
| Phone: (229) 546-5345 Email: mcdanielelectricllc@yahoo.com | Dale | 03/10/2010 |
| Description | | Total |
| 12x12 tower building wiring Lenox Ga. | | \$1,527.00 |
| The following is a quote for installing the following: | | |
| A 100 amp service for building power 3 wrap around fixtures for interior lighting 1 porch light for exterior lighting 10 receptacles 120 volt 20 amp rated | | |
| All lighting will be LED and will have a 5 year warranty from lighting will be controlled by individual switches from inside | manufacturer. Indoor and outo building | loor |
| All receptacle outlets will be installed like described in email it's on breaker and AC outlet will be on it's on breaker. | il sent by Lamar Ray. Each wall v | vill be on |
| All wiring will be armored cable or will be installed in conducted codes | it to meet or exceed local build | ing |

| Subtotal | \$1,527.00 |
|----------|------------|
| Total | \$1,527.00 |

Financing options are available

1

J

MCDANIEL ELECTRIC LLC

We offer financing through industry leading partners. Loans range from \$1,000 to \$100,000 with APR's as low as 6.16%. Check your rate in minutes without affecting your credit score. In proud partnership with:

Teeneralise and the Sort as

Charles Pafford

STATEMENT C & P ELECTRICAL & PLUMBING

P.O. Box 124 • Statenville, GA 31648 Phone 230-559-2009 • 929-359 8099 2 29 -567 • 2 00 2-

Date 10 - 1 20/8

Look County Commissioners Communication building

.

| Qty. | Description | | Amount | |
|------|--|--------|--------|---------|
| | To install cleat | ial | | |
| | To install clect to speck shee with 100 mp 3 | + | | |
| | with 100 mo S | (in ce | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | . TAX | | | |
| | | | | |
| | Parts # LABOR | | | |
| | | | | 15 |
| | TOTAL | | 2,375. | |

BP 24 807



October 1, 2018 Cook County Commissioners 12'x 12' Tower Building

Total Price \$2,700.00

10-Receptacles 3-Lights and switch 1-Porch light and switch 100 amp service Lights on 1 breaker A/C receptacle on 1 breaker Each wall on a circuit

> (229)546-7260 | coneelectric@contractor.net | GA Lic. # EN216359 P.O. Box 209 | Adel, GA 31620